

NABERSNZ

ENERGY RATING REPORT

This report provides more information about your NABERSNZ™ Energy Certified Rating and greenhouse gas emissions.



Certified Energy Rating Report for:

Building: 48 Emily Place
Address: 48 Emily Place
Auckland CBD 1010, Auckland
Rating type: Whole Building

Rating no: 23080013
Rating expires: 30 March 2024

Your Certified Rating:

This rating demonstrates
excellent performance



Your Rating details:

Rated area: 2,560m²
Rated hours: 48.3
hours per week
No of computers: 148

Energy consumption details

Electricity: 385,273 kWh	Coal: 0 Tonne
Gas: 0 MJ	LPG: 0 MJ
Liquid fuel: 0 MJ	Wood: 0 Tonne

The energy intensity of your premises: 150.5 kWh/m² p.a.
Indicative total greenhouse gas emissions¹: 51,098.4 kg CO₂-e p.a.
Greenhouse gas intensity¹: 20.0 kg CO₂-e/m² p.a.

¹Greenhouse gas (GHG) emissions figures above are calculated using GHG coefficient averages and are therefore indicative only.

